



THULAMELA MUNICIPALITY

ADDENDUM No.1

Thulamela Local Municipality is hereby issuing an addendum for an advertisement which was posted on Thulamela notice board and website dated **25 October 2023**, with reference to:

BID No. 36/2023/2024: UPGRADING OF THOHOYANDOU BLOCK M STREETS PHASE 1

Thulamela Local Municipality would like to inform prospective bidders that there were some changes made to the BOQ and herewith consists of the following:

1. NOTICE IS HEREBY GIVEN TO CORRECT THE BILL OF QUANTITIES ITEMS:


- 1.1. SECTION 2200 PREFABRICATED CULVERTS; ITEM 22.03 item a) 600 diam..., b 750 diam... and c, 900 dia.....**Unit (referenced to dia. Size) and class of the pipes is not provided, all the pipes should be priced at unit of **mm and class unit measurement 100D.**
- 1.2. SECTION 3400 PAVEMENT LAYERS OF GRAVEL MATERIAL;** Special item **B34.01** Crushed Stone Subbase does not specify if the material is obtainable from the **borrow pit or commercial source** nor does the specification therefore the item ii) 150mm G2 layer thickness.... Should read ii) **Constructed from type G2 materials obtained from the commercial source and compacted to 100% MODASHTTO (150mm).**
- 1.3. THE CALCULATION OF TENDER SUM** summary included Contract Price Adjustment (CPA) of 7.5%, this tender does not include CPA allowances therefore CPA does not form part of pricing.

section.

Please note that the closing date for the above-mentioned Bid No. 36/2023/2024 will remain the 28th of November 2023 at 11h00.

The prospective bidders who have already submitted their documents with reference to this BID are advised to come and pick them up so that they can also consider the information on this erratum. The contact details for those who want to pick up their documents are as per the advertisement.

Thulamela Municipality kindly regret any inconvenience caused.



MR. MAKUMULE M.T.

MUNICIPAL MANAGER

20.11.2023

DATE



THULAMELA LOCAL MUNICIPALITY

BID NUMBER.: 36/2023/2024

UPGRADING OF THOHoyANDOU BLOCK M STREETS PHASE 1

ADDENDUM NO. 1

THIS DOCUMENT IS COMPILED BY: THULAMELA LOCAL MUNICIPALITY

THULAMELA LOCAL MUNICIPALITY (CIVIC CENTRE, OLD AGRIVEN BUILDING)

Private Bag X5066

Thohoyandou

0950

TEL: (015) 962 7631/7629

FORM FOR RECEIPT OF ADDENDUM NO.1

NB: This form is for the receipt of Addendum No.1. It must be completed by the Tenderer and returned with your bid proposals to:

THULAMELA MUNICIPALITY (CIVIC CENTRE, OLD AGRIVEN BUILDING)

Private Bag X5066

I/We acknowledge receipt of Addendum No.1 and have noted its contents.

SIGNED ON BEHALF OF TENDERER :

NAME OF SIGNATORY :

NAME AND ADDRESS OF TENDERER

.....

.....

.....

TEL NO :

FAX NO :

DATE :

ADDENDUM NO 1

15 NOVEMBER 2023

ISSUED BY:

THULAMELA MUNICIPALITY (CIVIC CENTRE, OLD AGRIVEN BUILDING)

Private Bag X5066

Thohoyandou

0950

NAME OF TENDERER:

ADDENDUM NO.1

This Addendum forms part of the Tender Documents.

Each Tenderer for this Contract shall incorporate the following amendments and additions in their Tender.

Each Tenderer is required to acknowledge receipt and acceptance of the amendments and additions contained in this Addendum and to submit the completed and signed addendum with his Tender.

No Pages may be removed from the Addendum.

ADDENDUM NO.1

Addendum No.1 consists of the following changes in the tender document:

1. NOTICE IS HEREBY GIVEN TO CORRECT THE BILL OF QUANTITIES ITEMS:

- 1.1. SECTION 2200 PREFABRICATED CULVERTS; ITEM 22.03 item a) 600 diam...., b) 750 diam... and c), 900 diam.....**Unit (referenced to diameter Size) and class of the pipes is not provided, all the pipes should be priced at unit of **mm and class unit measurement 100D.**
- 1.2. SECTION 3400 PAVEMENT LAYERS OF GRAVEL MATERIAL; Special item B34.01** Crushed Stone Subbase does not specify if the material is obtainable from the **borrow pit or commercial source** nor does the specification therefore the item ii) 150mm G2 layer thickness.... Should read ii) **Constructed from type G2 materials obtained from the commercial source and compacted to 100% Mod AASHTO or 85% Bulk Relative Density (150mm).**
- 1.3. THE CALCULATION OF TENDER SUM** summary included Contract Price Adjustment (CPA) of 7.5%, this tender does not include CPA allowances therefore CPA does not form part of pricing.

NOTE: In light of the above changes, we have included the sections

ACCEPTANCE AND INCORPORATION OF ADDENDUM

I/We accept that Addendum No.1 forms part of the Tender/Bid Document
I/We confirm that I/We -;

- a) have noted the contents of this addendum
- b) have full considered this addendum
- c) have incorporated the amendments and additions contained in this
Addendum in my/our Tender for **Bid No: 36/2023/2024**

SIGNED ON BEHALF OF THE TENDERER.....

NAME OF THE SIGNATORY (BLOCK LETTERS)

NAME OF TENDERER (BLOCK LETTERS)

TENDERER'S ADDRESS.....

.....

TENDERER'S TEL NO:.....TENDERER'S FAX NO.....

SIGNATURES OF WITNESSES : 1.....

2.....

NAME OF WITNESSES : 1.....

LI	(a) Excavating soft material situated within the following depth ranges below the surface level:				
	(i) 0m up to 1,5m	m³	954		
	(ii) Exceeding 1,5m up to 3,0m	m³	191		
	(iii) Exceeding 3,0m up to 4.5m	m³		Rate Only	
	(iii) Exceeding 4,0m up to 6,0m	m³		Rate Only	
	(b) Extra over subitem 22.01(a) for excavation in hard material irrespective of depth	m³	114		
22,02	Backfilling:				
LI	(a) Using the excavated material	m³	458		
	(b) Using imported selected material	m³	229		
	(c) Extra over subitems 22.02(a) and 22.02(b) for soil cement backfilling (3% cement)	m³	55		
22/B3300	Foundation fill consisting of :				
	(a) Rock fill	m³	134		
	(b) Crushed-stone fill	m³	36		
22.03	Concrete pipe culverts:				
	a) 600mm dia. 100D on class C Bedding	m	180		
	b) 750mm dia. 100D diam on class C Bedding	m	Rate Only	Rate Only	
	C) 900mm dia. 100D on class C Bedding	m	Rate Only	Rate Only	
22,04	Portal and rectangular culverts:				
	(b) On class B bedding				
	(i) 1200mm (W) x 1200mm (H) (Class 75S)	m	120		
	(i) 900mm (W) x 600mm (H) (Class 75S)	m	Rate only	Rate only	
22,07	Cast in situ concrete and formwork:				
	(b) In floor slabs for portal or rectangular culverts,				

	blocks, excluding formwork but including Class U2 surface finish:								
	(i) Class 25/19 concrete	m ³	34						
	(d) Formwork of concrete under subitem 22.07(c)								
	(i) Vertical formwork for F1 surface finish	m ²	55						
	(ii) Vertical formwork for F2 surface finish	m ²	110						
22,10	Steel reinforcement:								
	(b) High tensile steel bars	t	6						
	(c) Welded steel fabric REF 395	kg	360						

	borrow, including free-haul up to 1,0 km: (a) Gravel selected layer compacted to: (i) 150mm Lower SSG G6 layer thickness to 93% modified AASHTO density (ii) 150mm Upper SSG G6 layer thickness to 95% modified AASHTO density (f) Gravel subbase (chemically stabilized material) compacted to : (i) 150mm G6 layer thickness to 97% of modified AASHTO density (g) Gravel shoulder compacted to: (ii) 95% of modified AASHTO density (150 mm compacted layer thickness)	m³	2327				
		m³	2327				
		m³	Rate Only		Rate Only		
		m³	846				
B34.01	(c) Crushed Stone subbase compacted to						
	(ii) Constructed from type G2 materials obtained from commercial source and compacted to 100% ModASHTTO at 150mm layer	m³	2291,25				
34/16.02	Overhaul on material hauled in excess of 1.0 km(ordinary overhaul)	m³.km	22102				

	borrow, including free-haul up to 1,0 km: (a) Gravel selected layer compacted to: (i) 150mm Lower SSG G6 layer thickness to 93% modified AASHTO density (ii) 150mm Upper SSG G6 layer thickness to 95% modified AASHTO density (f) Gravel subbase (chemically stabilized material) compacted to : (i) 150mm G6 layer thickness to 97% of modified AASHTO density (g) Gravel shoulder compacted to: (ii) 95% of modified AASHTO density (150 mm compacted layer thickness)	m ³	2327			
		m ³	2327			
		m ³	Rate Only		Rate Only	
		m ³	846			
B34.01	(c) Crushed Stone subbase compacted to (ii) Constructed from type G2 materials obtained from commercial source and compacted to 100% ModASHTTO at 150mm layer	m ³	2291,25			
34/16.02	Overhaul on material hauled in excess of 1.0 km(ordinary overhaul)	m ³ .km	22102			



CALCULATION OF TENDER SUM

ITEM	AMOUNT
TOTAL SCHEDULE A: ROADWORKS	
TOTAL SCHEDULE B: ENVIRONMENTAL MANAGEMENT PLAN	
TOTAL SCHEDULE C: STRUCTURED TRAINING	
TENDER (CONTRACT) SUM	
CONTINGENCIES (10%)	
SUB-TOTAL	
ADD 15% VAT	
TENDER (CONTRACT) PRICE CARRIED TO FORM OF OFFER OF ACCEPTANCE (Page C.3)	